



## Certificate of conformity

Issued in conformity with the transposition decree number 92-647 of 8 July 1992, modified by the decree number 95-1051 of 20 September 1995 and the decree number 2003-947 of 3 October 2003 concerning appropriate use of construction products and in conformity with article 14 (1) (b) of the Construction Products Directive (89/106/EEC) of 21 December 1988 amended by the Directive 93/68/EEC of 22 July 1993.

**Delivered by :**

Notified Body :

**AFNOR Certification**

Identification number :

**0333**

Address :

**11 rue Francis de Pressensé  
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

**Delivered to :**

Company:

**FARE**

Address :

**ZA de la Guinette  
rue Duhamel de Monceau  
45300 DADONVILLE - France**

Manufacturing site :

**Dadonville - France**

**Product : Point heat detector with input / output device and short-circuit isolator - TA 05**

**Detailed description of product : Annex**

The product mentioned in annex is the object by the manufacturer of a factory production control and tests carried out on samples taken in the place of manufacture in accordance with a pre-established test plan.

AFNOR Certification carried out tests of the initial type on the product, the initial inspection of the site of production and the control of production in factory and carries out a continuous surveillance, evaluation and an acceptance of the control of production in factory.

This certificate attests that provisions concerning the attestation of conformity described in annex ZA of the standard(s), below stated, were applied and that the product fulfills all the requirements demands.

It will allow the manufacturer or his agent operating within the EEA to apply EC marking

**Fire detection and fire alarm systems**

**EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors**

**EN 54-17:2005 - Short-circuit isolators**

**EN 54-18:2005 - Input/output devices - Sounders**

Certificate number :

**0333-CPD-075112**

Conditions and certificate validity period : **14 March 2016**

This certificate was first issued on 15 March 2006. It remains valid until cancelled or withdrawn as a result of decisions taken in case of non-compliance or significant changes in product, production or production control. It cancels and replaces the certificate issued on 19 November 2010.

Date of certificate delivery : **21 March 2011**



Deputy General Manager

Vlo

**Jacques BESLIN**



# Certificat

## Certificate

### Certificate of conformity Annex

Company : FARE  
Certificate number : 0333-CPD-075112  
Manufacturing site : Dadonville - France  
Date of certificate delivery : 21 March 2011

#### Product's description :

Identification of certified product (Reference)	Product designation / Use	File number
TA 05	Point heat detector with input / output device and short-circuit isolator  Class : A1R, A1S, A2R, A2S, BR and BS Optional short-circuit isolator, card ICC 05, integrable in base S05 Optional Input/Output device with card R05	CE075-05-059 075.0013