



Certificat

Certificate

Certificat de conformité à la norme :

Systemes de détection et d'alarme Incendie EN 54-4 Equipement d'alimentation électrique

Délibré conformément au décret de transposition N°92-647 du 8 juillet 1992, modifié par les décrets N° 95-1051 du 20 septembre 1995 et n°2003-947 du 3 octobre 2003 concernant l'aptitude à l'usage des produits de construction et à l'article 14 (1) (b) de la Directive Produits de la Construction 89/106/CEE du 21 décembre 1988 amendée par la Directive 93/68/CEE du 22 juillet 1993.

Délibré par :

Organisme notifié : **AFNOR Certification**
Numéro d'identification : **0333**
Adresse : **11, rue Francis de Pressensé
FR-93571 La Plaine Saint-Denis Cedex**

Délibré à :

Société : **SEFI**
Adresse : **ZI rue René Cassin
45308 PITHIVIERS - FRANCE**

Lieu de fabrication : **Pithiviers, FRANCE**

Produit(s) : Equipement d'Alimentation Electrique – HEPHEA 248

Description détaillée du produits : Voir annexe (1 page)

Le produit mentionné ci-dessus fait l'objet par le fabricant d'un contrôle de production en usine et à des essais réalisés sur des échantillons prélevés sur le lieu de fabrication conformément à un programme d'essais préétabli.

AFNOR Certification a effectué les essais de type initiaux sur ce produit, l'inspection initiale du site de production et du contrôle de production en usine et effectue une surveillance continue, une évaluation et une acceptation du contrôle de production en usine.

Ce certificat atteste que les dispositions concernant l'attestation de conformité décrites dans l'annexe ZA de la norme EN 54-4 : 1997 + A1 : 2002 + A2 : 2006 ont été appliquées et que le produit remplit toutes les exigences imposées. Il permet au fabricant ou à son mandataire établi dans l'EEE d'apposer le marquage CE.

Numéro de certificat : **0333-CPD-075303**

Conditions et période de validité du certificat : **27 octobre 2014**

Ce certificat a été délivré pour la première fois le **28 octobre 2009**. Il reste valable jusqu'à son annulation ou son retrait à la suite de décisions prises en cas de non-conformité ou de modifications significatives du produit, de production ou de contrôle de production.

Date d'émission du certificat : **le 28 octobre 2009**

Le Directeur Général Délégué



Jacques BESLIN





Certificat

Certificate

Certificat de conformité à la norme :
EN 54-4
Annexe (1 page)

Société : **SEFI**
Numéro de certificat : **0333-CPD-075303**
Lieu de fabrication : Pithiviers, FRANCE
Date d'émission du certificat : **le 28 octobre 2009**

Description du produit :

Identification du produit certifié (référence)	Désignation du produit selon la norme (classification)	Utilisation du produit	Numéro de dossier
HEPHEA 248	Equipement d'Alimentation Electrique	Source d'alimentation principale : 230 Vac – 50 Hz Alimentation de secours : 2 Batteries de 12 V – 24 Ah Tension finale des batteries : 21 V Nombre de sorties : 2 Tension nominale des sorties : 27.2 V Alimentation de type : à découpage	075.0354



Certificate of conformity with standards:

Fire detection and fire alarm systems EN 54-4 Power supply equipment

Issued in conformity with the transposition decree number 92-647 of 8 July 1992, modified by the decree number 95-1051 of 20 September 1995 and the decree number 2003-947 of 3 October 2003 concerning appropriate use of construction products and in conformity with article 14 (1) (b) of the Construction Products Directive (89/106/EEC) of 21 December 1988 amended by the Directive 93/68/EEC of 22 July 1993.

Delivered by :

Notified Body : **AFNOR Certification**
Identification number : **0333**
Address : **11, rue Francis de Pressensé
FR-93571 La Plaine Saint-Denis Cedex**

Delivered to :

Company: **SEFI**
Address : **Rue René cassin – BP 90817
45308 PITHIVIERS Cedex- France**

Manufacturing site : **Pithiviers, FRANCE**

Products : Power Supply Equipment – HEPHEA 248

Detailed description of product : Annex (1 page)

The product mentioned in annex is the object by the manufacturer of a factory production control and tests carried out on samples taken in the place of manufacture in accordance with a pre-established test plan.

AFNOR Certification carried out tests of the initial type on the product, the initial inspection of the site of production and the control of production in factory and carries out a continuous surveillance, evaluation and an acceptance of the control of production in factory.

*This certificate attests that provisions concerning the attestation of conformity described in annex ZA of the standards EN 54-4 : 1997 + A1 : 2002 + A2 : 2006 were applied and that the product fulfils all the requirements demands.
It will allow the manufacturer or his agent operating within the EEA to apply EC marking.*

Certificate number : 0333-CPD-075303

Conditions and certificate validity period : 27 October 2014

This certificate was first issued on **28 October 2009** and remains valid as long as the validity period and the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Date of certificate delivery : **28 October 2009**

Deputy General Manager

Jacques BESLIN



Certificat

Certificate

Certificate of conformity with standards:
EN 54-4
Annex (1 page)

Company : **SEFI**
Certificate number : **0333-CPD-075303**
Manufacturing site : Pithiviers, FRANCE
Date of certificate delivery : 28 October 2009

Product's description :

Identification of certified product (Reference)	Product designation in compliance with standards	Technical product type	File number
HEPHEA 248	Power Supply Equipment	Main power source : 230 Vac – 50 Hz Standby power source : 2 Batteries de 12 V – 24 Ah Final voltage of batteries : 21 V Number of outputs : 2 Nominal voltage of outputs : 27.2 V Type of power supply : switching mode	075.0354