



Certificat

Certificate

Certificate of conformity

Issued in conformity with the transposition decree number 92-647 of 8 July 1992, modified by the decree number 95-1051 of 20 September 1995 and the decree number 2003-947 of 3 October 2003 concerning appropriate use of construction products and in conformity with article 14 (1) (b) of the Construction Products Directive (89/106/EEC) of 21 December 1988 amended by the Directive 93/68/EEC of 22 July 1993.

Delivered by :

Notified Body :

AFNOR Certification

Identification number :

0333

Address :

**11 rue Francis de Pressensé
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

Delivered to :

Company:

FARE

Address :

**ZA de la Guinette
rue Duhamel de Monceau
45300 DADONVILLE - France**

Manufacturing site :

Dadonville - France

Product : Optical smoke detector with input / output device and short-circuit isolator - MA05

Detailed description of product : Appendix

The product mentioned in appendix is the object by the manufacturer of a factory production control and tests carried out on samples taken in the place of manufacture in accordance with a pre-established test plan.

AFNOR Certification carried out tests of the initial type on the product, the initial inspection of the site of production and the control of production in factory and carries out a continuous surveillance, evaluation and an acceptance of the control of production in factory.

This certificate attests that provisions concerning the attestation of conformity described in annex ZA of the standard(s), below stated, were applied and that the product fulfills all the requirements demands.

It will allow the manufacturer or his agent operating within the EEA to apply EC marking

Fire detection and fire alarm systems

EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors using scattered light, transmitted light or ionization

EN 54-17:2005 + AC:2007 - Short-circuit isolators

EN 54-18:2005 + AC:2007 - Input/output devices - Sounders

Certificate number :

0333-CPD-075159

Conditions and certificate validity period : **14 November 2016**

This certificate was first issued on 22 November 2006. It remains valid until cancelled or withdrawn as a result of decisions taken in case of non-compliance or significant changes in product, production or production control. It cancels and replaces the certificate issued on 9 June 2011.

Date of certificate delivery : **15 November 2011**

Managing Director

Florence MÉAUX



Ref 013 - 07/2010



Certificat

Certificate

Certificate of conformity Appendix

Company : FARE
Certificate number : 0333-CPD-075159
Manufacturing site : Dadonville - France
Date of certificate delivery : 15 November 2011

Product's description :

Identification of certified product (Reference)	Product designation / Use	File number
MA05	Optical smoke detector with input / output device and short-circuit isolator Optional short-circuit isolator, card ICC 05, integrable in base S05 Optional Input/Output device with card R05	CE075-06-026 075.0016 075.0653